GREENFIELD WATER UTILITY



451 Meek Street Greenfield, Indiana 46140 www.greenfieldin.org Phone: (317) 477-4350

13 May 2025

Mayor Guy Titus Board of Works and Public Safety 10 South State St. Greenfield, IN 46140

Re: Well Maintenance Task Order 2-5

Mayor and Board Members,

Municipal Water Well 2-2 has been found during routine maintenance inspection to require cleaning and service. This work will consist of pulling the well pump, pre-cleaning camera inspection, double disk surge cleaning of the well casing and screen, post-cleaning camera inspection and reinstallation of the pump. This work is consistent with our PSA with Peerless Mid-West and through Task Order 2-5 this work will be performed.

I request the Board approve Task Order 2-5 as presented in the amount of \$ 21,870 to be completed as soon as possible.

Respectfully Submitted,

Charles Gill

Water Utility Manager

cc: Jane Webb, Utility Coordinator Lori Elmore, Clerk-Treasurer

GREENFIELD WATER UTILITY



451 Meek Street Greenfield, Indiana 46140 www.greenfieldin.org Phone: (317) 477-4350

TASK ORDER NO. 2-5 TO CONTINUING PROFESSIONAL SERVICES AGREEMENT Between City of Greenfield (Owner) and Peerless Midwest, Inc. (Engineer) Date of Original Executed Agreement: 27 December 2022

TASK ORDER NAME/DESCRIPTION

Task 2- 5: Well Cleaning and Service

The purpose of this Task Order is to provide all parts, materials, and labor for the cleaning of City of Greenfield Municipal Water Well 2-2.

A. SCOPE OF SERVICES

Engineer's proposed task under this scope of services are as follows:

1. Clean Well in accordance with state laws and requirements

- 1.1. Provide 2-person crew to perform flow test, recording GPM, static water level, pumping water levels at pump design.
- 1.2. Provide 2-person crew with crane to pull the existing pumping equipment.
- 1.3. Provide Hydrologist to camera inspect well casing and screen prior to cleaning.
- 1.4. Double Disk Clean Well casing and screen with the addition of chemicals as developed for the City of Greenfield Well Systems.
- 1.5. Provide Hydrologist to camera inspect well casing and screen after to cleaning.
- 1.6. Inspection Report to be submitted to owner as soon as possible after completion of both preand post-cleaning inspections.
- 1.7. This vertical turbine pump and motor will be hauled to our shop for teardown and inspection then quote repairs recommended to the pumping equipment or replacement if necessary.

B. KEY STAFF

ENGINEER shall include all subcontractors relevant to the scope of services in this task order. ENGINEER may not remove or otherwise substitute subcontractors indicated on without consent of OWNER. A failure by ENGINEER to provide the subcontractors as required by this Article shall be considered a material breach of the Agreement.

- 1. Utility Manager Charles Gill
- 2. Assistant Utility Manager Jimmy Griffith
- 3. Project Manager Nick Rice

Note: Engineer reserves the right to assign additional staff as needed to complete Work of the Project.

GREENFIELD WATER UTILITY



451 Meek Street Greenfield, Indiana 46140 www.greenfieldin.org Phone: (317) 477-4350

C. PROJECT TIMING

Task Order shall be completed by the ENGINEER and delivered to the GREENFIELD DEPARTMENT OF ENGINEERING (OWNER) according to the schedule below.

Engineer is authorized to proceed approval of this Task Order by City of Greenfield.

D. COMPENSATION

 Compensation for the work as defined in the Scope of Services of this Task Order shall be in accordance with ENGINEER's standard charge out rates in effect at the time the Services are performed. Routine expenses will be billed at cost and sub-consultant costs will include a 10% markup. The total cost for these Services and expenses are as follows:

Lump sum amount \$ 21,870 If additional days are needed to complete this process per day sum is \$ 3,480

- 2. ENGINEER will bill Owner monthly, with net payment due in 30 days.
- 3. ENGINEER will notify Owner if Project scope changes require modifications to the abovestated contract value. Services relative to scope changes will not be initiated without written authorization from Owner.

APPROVED FOR OWNER	APPROVED FOR ENGINEER
Ву:	By: _Peerless Midwest Inc
Printed Name:	Printed Name: Nick Rice
Title:	Title: <u>Project Manager</u>
Signature:	Signature: Nick Rice