



Addendum No. 1

Project Name: Fortville Pike & C.R. 300 N Intersection Reconstruction
Project Number: 2205FFE
Date: October 4, 2024

OWNER:

City of Greenfield
10 S State Street
Greenfield, IN 46140

DESIGNER:

American Structurepoint, Inc.
9025 River Road, Suite 200
Indianapolis, Indiana 46240
317.547.5580

This Addendum forms part of the Contract Documents for the Project and contains clarifications and revisions to the Contract Documents.

The information contained herein modifies the original Bidding Documents and all prior Addenda as applicable. Requirements of the original Bidding Documents and previous Addenda remain in effect except as modified by this Addendum.

Bidders must acknowledge receipt of this Addendum within Part 4 of the Project Manual. Failure to acknowledge receipt of this Addendum may subject Bidder to disqualification.

October 4, 2024

The extent of this addendum is as follows:

ITEM # 1 – Pre-Bid Meeting Minutes

1. Meeting Minutes from 9/30/2023 Pre-Bid Meeting Included.

ITEM #2 – Project Manual

1. Part 1 Bidder's Itemized Proposal and Declarations – the itemized proposal form has been added to the Project Manual
2. Technical Specifications – Additions and/or deletions are shown in **RED** in the accompanying document.
 - a. TS 26 – Completion Dates and Liquidated Damages. Substantial completion date revised to 8/29/2025 and final completion date revised to 9/26/2025.
 - b. TS 27 – Roadway Closure. Closure period extended to 75 days. Further information added prescribing closure to begin no sooner than the end of the school year and requiring emergency access through the closure.
 - c. TS 28 – Utility/Right of Way. Additional information added on status of utilities.
 - d. TS 35 – Language added directing Contractor to coordinate with the City regarding acquisition of the light poles for the project.
 - e. TS 42 – Water Supply. Specification added to contract.

ITEM #3 – Construction Plans

1. PDF Page 27 – Irrigation Plans. 1.25" PVC Class 1 SDR 21 Service Line revised to 1" Copper Type K Service Line.
2. PDF Page 27 – Irrigation Plans. 1.25" Corporation Valve revised to 1" Corporation Valve.
3. PDF Page 29 – Lighting Details. General Note 5 added. Galvanized steel conduit revised to PVC Conduit. Cable Duct Markers added.

ITEM #4 – Utility Work Plans

1. Centerpoint Energy work plan added.

If you wish to submit a bid, please do so according to the information provided in this ADDENDUM No. 1.



M E E T I N G M I N U T E S

DATE: 09/30/2024

RE: Pre-Bid Meeting: 2205FFE – Fortville Pike & CR 300 N Intersection
Reconstruction

MINUTES IN BLUE

Meeting Location: Larry Breese Conference Room – 10 S State Street, Greenfield, IN, 46140

Meeting Date: September 30, 2024

Meeting Time: 9:30 AM EDT

Owner: City of Greenfield

Discussion Items:

1. Sign-in / Introductions
 - a. Project Team
 - i. City of Greenfield
 - ii. American Structurepoint
2. Project Description
 - a. Reconstruction of the existing Fortville Pike/CR 300 N 4-way stop intersection to a single lane roundabout
 - b. Proposed improvements include, storm sewer, pedestrian facilities, landscaping in the center island and roundabout lighting..
3. Bidding Schedule
 - a. 09/21/2024 – First Advertisement Plans made available for contractors
 - b. 09/28/2024 – Second Advertisement
 - c. 09/30/2024 – This pre-bid meeting
 - d. 10/07/2024 – Last day for contractor questions
 - e. 10/22/2024 @ 9:30am EDT – Bid Opening
 - f. Anticipated Addenda
 - i. 0910/04/2023 – Addendum 1 issued w/pre-bid minutes & minor irrigation detail update
 - ii. 10/14/2023 - Addendum 2 issued (as needed)
4. Traffic Maintenance
 - a. 45 consecutive calendar day closure.



- i. Due to EMS response concerns, extension of closure duration will be included in Addendum 1 so access can be maintained for emergencies.
 - b. Anticipated that closure will occur during the summer months.
 - i. Due to EMS response concerns, extension of closure duration will be included in Addendum 1 so access can be maintained for emergencies. Closure may extend into beginning of school year.
 - c. Notice shall be provided to schools if traffic restrictions occur while school is in session
 - d. Notice shall be provided to all emergency services prior to closure of intersection.
- 5. Permits
 - a. Construction Storm Water General Permit – Received 1/24/2024
- 6. Utilities
 - a. Approved Utility Work Plans:
 - i. Ninestar Connect – Electric
 - ii. Ninestar Connect - Communications
 - iii. Everstream
 - iv. Duke Energy – Transmission
 - v. AT&T
 - vi. Centerpoint Energy
 - b. Pending Utility Work Plans:
 - i. Comcast
 - c. Utilities that will be relocating:
 - i. Ninestar Connect - Electric
 - ii. Ninestar Connect – Communications (underbuild on Ninestar poles)
 - iii. Everstream
 - iv. AT&T (underbuild on Ninestar poles)
 - v. Comcast (underbuild on Ninestar poles)
 - d. Utilities that have relocated:
 - i. Centerpoint Energy
- 7. Right of Way
 - a. All three (3) parcels are secure.
[Contractor to ensure all vehicles and operations stay within City rights of way](#)
- 8. Notable Items
 - a. Utilities to be relocated over the winter/early spring
 - b. Contractor NTP anticipated for 12/12/2024
- 9. Questions?
 - a) [Questions may be submitted after 10/07/2024, \(the last day for contractor questions\).](#) However, Engineer will decide if question will be answered or not.



- b) Engineer to provide itemized proposal with all pay items with Addendum 1.
- c) Conduits that cross the road will be changed from galvanized to PVC with markers at the end points. This change will be issued with Addendum 1.
- d) Light poles
 - I. City to provide power to service point for light poles.
 - II. Note to Construction Plans will be added noting City to supply light poles and luminaires for contractor. Contractor will still be responsible for foundations all other necessary items for the light pole installation.
 - III. Upon receipt of poles and luminaires, contractor will assume all responsibility.
- e) No water shall be taken from hydrants. Contractor to coordinate with City of Greenfield Water (Charles Gill).