



FIRE DEPARTMENT CONNECTION (FDC)

NOTES:

1. THE FDC SHALL MEET OR EXCEED THE REQUIREMENTS OF THE MOST RECENT STATE OF INDIANA ADOPTED EDITION OF NFPA 13 OR NFPA 14.
2. THE FDC SHALL BE LOCATED OFF THE BUILDING IN A LOCATION APPROVED BY THE GREENFIELD FIRE DEPARTMENT.
3. THE FDC SHALL BE PROVIDED WITH A SINGLE 5" STORZ CONNECTION THAT SHALL FACE TOWARDS THE NEAREST POINT OF FIRE DEPARTMENT ACCESS.
4. THE FDC SHALL BE CONSTRUCTED OF A MATERIAL NOT SUSCEPTIBLE TO DEGRADATION.
5. THE FDC SHALL NOT BE LOCATED MORE THAN 150' FROM THE NEAREST FIRE HYDRANT.
6. REFER TO FIRE SUPPRESSION DESIGN DRAWINGS FOR ADDITIONAL INFORMATION.