



GREENFIELD WATER UTILITY

451 Meek Street • Greenfield, Indiana 46140

Telephone (317) 477-4350

Fax (317) 477-4351

Email: water@greenfieldin.org

URL: <http://www.greenfieldin.org/water>

CONSUMER CONFIDENCE REPORT FOR THE CITY OF GREENFIELD WATER UTILITY, INDIANA PUBLIC WATER SYSTEM IDENTIFICATION NUMBER 5230004

A Consumer Confidence Report is an annual report for customers on the quality of drinking water provided by a community water system. This is a requirement that was written into the 1996 Safe Drinking Water Act Amendments. The United States Environmental Protection Agency published the final regulations on August 19, 1998. Consumer Confidence Reports are required to be provided annually by all community water systems. This report is required to be distributed by mail to all customers of systems serving a population greater than 10,000. All affected water systems will be required to provide Consumer Confidence Reports no later than 14 months after promulgation of the final EPA rule (October 1999). This report must contain data for 2013. Each subsequent report is due on July 1 (i.e., 2013 data on July 1, 2014). For the year 2013, the City of Greenfield Water Utility met all EPA and State drinking water health standards.

WATER SYSTEM INFORMATION

Questions or comments on this report may be directed to Mr. Michael Fannin, Supt. of the Greenfield Water Utility at phone number 477-4350 or Mr. Bob Lane, Sr. Water Plant Operator for the Greenfield Water Utility at phone number 477-5350. Normal Business hours are 8am-4pm Monday through Friday. The Greenfield City Council meets every second and fourth Wednesday of the month at 7:00pm in the Council Chambers of Greenfield City Hall. City Hall is located at 10 South State Street in Greenfield. The Greenfield Board of Public Works and Safety meets every second and fourth Tuesday of the month at 10:00am in the Council Chambers of Greenfield City Hall. These public meetings provide an opportunity for public participation in decisions that affect drinking water quality.

SOURCE OF WATER FOR GREENFIELD

The City of Greenfield Water Utility draws water from aquifers in Greenfield. The water is pumped from the City wells to the Filtration Plants and then put through the filtration and disinfection process. It is then sent into the water distribution system. The total capacity of all plants is seven million gallons per day, with the capability to expand to eleven million gallons per day. The City currently averages approximately three million gallons per day. A Wellhead Protection Program is in place. Wellhead Protection is available for viewing upon request.

EDUCATIONAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline @ 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice from their health care providers. EPA/CDA guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline @ 1-800-426-4791.

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming
- Pesticides and herbicides, which may come from a variety of sources such as agricultural, urban storm water runoff, and residential uses.
- Organic chemical contaminant, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring, or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

THIS REPORT, ALONG WITH OTHER VITAL INFORMATION CONCERNING THE CITY OF GREENFIELD, IS AVAILABLE ON THE CITY OF GREENFIELD WEB PAGE.

www.greenfieldin.org

“DEDICATED TO SAFE DRINKING WATER”

DEFINITIONS	
MAXIMUM CONTAMINANT LEVEL (MCL)	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MAXIMUM CONTAMINANT LEVEL GOAL (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
ACTION LEVEL (AL)	The concentration of a contaminant which if exceeded, triggers treatment or other requirements, which a water system must follow.
VARIANCES AND EXEMPTIONS	State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
Nd	No Detection
ppm	Parts per million, or milligrams per liter (mg/l)
ppb	Parts per billion, or micrograms per liter (ug/l)
pCi/l	Picocuries per liter (a measure of radioactivity)
MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL)	The highest level of disinfectant allowed in drinking water.
MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDG)	The level of a drinking water disinfectant below which there is no known risk to health.
DETECTED CONTAMINANTS	
A detected contaminant is any contaminant detected at or above its minimum detection limit (MDL). The State allows us to monitor for some contaminants less than once per year because concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one year old.	
If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Greenfield Water Utility is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline, or at http://www.epa.gov/safewater/lead .	
UNREGULATED CONTAMINANTS	
The purpose of monitoring for unregulated contaminants in drinking water is to provide data to support the EPA Administrator's decisions concerning whether or not to regulate these contaminants in the future for the protection of public health. The Greenfield Water Utility has tested for unregulated contaminants as required. A copy is available upon request.	
* Definitions that pertain to this report are above.	
** 90% of samples must be below the Action Level for Lead and Copper. Last required test in 2011	
*** The EPA considers 40 pCi/l to be the level of concern for Beta particles. Last required test 2008	
# The most recent tests available for compliance was taken in 2008	
## The most recent tests available for compliance was taken in 2012	
NOTE: The EPA requires monitoring for over 80 drinking water contaminants. The contaminants listed above are the only contaminants detected in Greenfield Municipal Water. Please understand that none of the compounds listed are at or above the limits established by the USEPA. For a complete list of contaminants that are tested, contact the Greenfield Water Utility.	
COMPLIANCE WITH OTHER DRINKING WATER REGULATIONS	
TREATMENT TECHINUES	NO VIOLATION
LEAD AND COPPER CONTROL REQUIREMENTS	NO VIOLATION
MONITORING AND REPORTING COMPLIANCE DATA	NO VIOLATION
RECORD KEEPING REQUIREMENTS	NO VIOLATION
VIOLATION OF A VARIANCE OR EXEMPTION	NO VIOLATION
VIOLATION OF AN ADMINISTRATIVE OR JUDICIAL ORDER	NO VIOLATION
SPECIAL MONITORING REQUIREMENTS	NO VIOLATION

GREENFIELD WATER QUALITY REPORT FOR 2013 *

SUBSTANCE	MCL	MCLG	DETECTED	RANGE	SOURCE
INORGANIC					
ARSENIC ##	10ppb	0ppb	1.5ppb	1ppb-1.5ppb	Erosion of natural deposits; Runoff from glass and electronics
BARIUM ##	2ppm	2ppm	1.07ppm	0.938ppm-1.07ppm	Discharge of drilling waste-metal of natural deposits
FLUORIDE (NATURAL) ##	4ppm	4ppm	0.8ppm	0.2ppm-0.8ppm	Erosion of natural deposits, discharge of aluminum & fertilizer factories
NICKEL ##	N/A	N/A	1.9ppb	Nd-1.9ppb	Erosion of natural mineral deposit various industrial processes such as coal gasification, petroleum refining, smelting/refining; surface runoff of ground water
LEAD AND COPPER AL					
LEAD **	15ppb	0ppb	5ppb	none over MCL	Corrosion of household plumbing, natural deposits
COPPER **	1.3ppm	1.3ppm	0.748ppm	none over MCL of 30 samples	Corrosion of household plumbing, natural deposits, leaching from water
SUBSTANCE	MCL	MCLG	DETECTED	RANGE	SOURCE
NITRATES					
NITRATE (measured as nitrogen)	10ppm	10ppm	.64ppm	Nd-0.64ppm	Runoff from fertilizer use, leaching from tanks, sewage, erosion of natural deposits
DISINFECTION BY-PRODUCTS					
HALOACETIC ACID	60ppb	N/A	9.34ppb	Nd-9.34ppb	By-product from disinfection
TOTAL TRIHALOMETHANES	80ppb	N/A	34ppb	16ppb-52ppb	By-product from disinfection
SPECIAL MONITORING REQUIREMENTS					
RADIONUCLIDES					
GROSS ALPHA#	15 pCi/l	0pCi/l	0.30pCi/l	0pCi/l-0.30pCi/l	Erosion of natural deposits
GROSS BETA ***	40 pCi/l	0pCi/l	3.7pCi/l	0.10pCi/l-3.7pCi/l	Decay of natural and man-made radionuclides
URANIUM#	30ppb	N/A	0.5ppb	0.5ppb-0.5ppb	Erosion of natural deposits
INORGANIC					
SODIUM (unregulated) ##	N/A	N/A	15.7ppm	14.1ppm-17.3ppm	
DISINFECTANT					
SUBSTANCE	MRDL	MRDLG	DETECTED	RANGE	
CHLORINE	4.0ppm	N/A	0.37ppm	0.29ppm-0.42ppm	
UNREGULATED CONTAMINANTS					
SUBSTANCE	MCL	MCLG	DETECTED	RANGE	SOURCE
MOLYBDENUM	N/A	N/A	15ppb	5ppb- 15ppb	Naturally-occurring element found present in plants, animals and bacteria used form molybdenum trioxide as a reagent
STRONTIUM	N/A	N/A	2500ppb	390ppb- 2500ppb	Naturally-occurring element; historical commercial use of strontium has been in faceplate glass of cathode-ray tube televisions to block x-ray emission
(DIOXANE) 1,4-DIOXIDE	N/A	N/A	.26ppb	Nd- .26ppb	Cyclic aliphatic ether, used as a solvent stabilizer in manufacture and processing of cotton, textile products, automotive cosmetics and shampoos.